



CITY OF MOUNTAIN VIEW

Fire Department ▪ Fire and Environmental Protection Division ▪ 500 Castro Street ▪ City Hall - 4th Floor
Mountain View, California 94041-2010 ▪ 650-903-6378 ▪ FAX 650-903-6101

6-MONTH FIXED FIRE PROTECTION SYSTEM SERVICE TEST REPORT (Updated 2/1/07)

The California Fire Code requires the following (engineered) fire protection systems to be maintained in an operative condition at all times. The maintenance, servicing and testing of these systems shall be in accordance with the appropriate nationally recognized National Fire Protection Association standards listed below. Engineered fire protection systems include, but are not limited to:

- Wet Chemical Extinguishing Systems –i.e. Kitchen Hood and Duct (NFPA 17A)
- Halon (or halon replacement) Extinguishing Systems- i.e. Computer Rooms (NFPA 12A/NFPA 2001)
- Dry Chemical Extinguishing Systems-i.e. Spray Paint Booths (NFPA 17)
- Carbon Dioxide Extinguishing Systems-i.e. Chemical Storage Sheds (NFPA 12)

In Mountain View, **documentation of the service, test and maintenance, along with any deficiencies found**, shall be submitted to the Mountain View Fire Department. The test shall only be conducted by a California State licensed contractor familiar with the system. While test procedures will vary according to the system, the information outlined below should be included with every test submittal.

Business Name: _____

Site Location (address): _____

System Description: _____

Testing Contractor: _____ License #: _____

Testing Contractor Address: _____ Phone: _____

Certification Date: _____

LIST DEFICIENCIES FOUND AND HOW/WHEN CORRECTED

Return completed form to:
**City of Mountain View
Fire and Environmental Protection Division
500 Castro Street, City Hall – 4th Floor
Mountain View, CA 94041-2010
Attn: Fire Marshal**